


**2019 Water Audit**  
Certified Validation Report



**Part A: Provided by Validator**

**Audit Information:**

Utility: Beverly Hills PWS ID: 1910156  
System Type: Potable Audit Period: Calendar 2019 Utility Representation: Mike Swan, Psomas  
Validation Call Date: 9/22/2020

**Validation Findings & Confirmation Statement:**

**Key Audit Metrics:**

Data Validity Score: 69 Data Validity Band (Level): Band III (51-70)  
ILI: 0.49 Real Loss: 7.75 (gal/conn/day) Apparent Loss: 11.50 (gal/conn/day)


**Certification Statement by Validator:**

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34. All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit.

**Validator Information:**

Water Audit Validator: Greg Ripperger Validator Qualifications: Water Audit Validator Certificate

**2019 Water Audit**  
Certified Validation Report



**Part B: Provided by Utility**

**Water Supplier Name:** Beverly Hills      **Water Supplier ID Number:** 1910156      **Water Audit Period:** Calendar 2019

**Water Audit & Water Loss Improvement Steps:**

*Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss, as informed by the annual validated water audit:*

City staff has continued its vigilance in determining unmetered uses such as street sweeping, sewer cleaning and water use for other maintenance purposes as well as estimating losses due to line breaks. A meter was recently installed at the yard to record some of these uses that are currently unmetered for more accurate accounting. City has now purchased and installed a meter testing bench, trained staff on its use and is testing meters in-house, the results of which will be available for next year's water loss audit.

**Certification Statement by Utility Executive:**

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software.

**Executive Name (Print):**

Vince Damasse

**Executive Position:**

Water Resources Manager

**Signature:**

Vince Damasse

**Date:**

9/25/20